

ANSI/API Standard 607 Sixth Edition – 2010

ISO 10497: 2010

Fire Test Certificate

Name of Manufacturer:	Valworx Inc.
Designation of Valve:	2-pc Flange End Ball Valve, 5530
Size:	2 inch
Body/Bonnet Material:	CF8M

Test Date:	October 22, 2013
Report/Certificate Number:	213075B
Pressure Rating:	Class 150
Seat/Stem Seal Material:	PTFE and Graphite

The above valve was tested in accordance with the above stated fire test procedure in both flow directions. All of the applicable test parameters were met and external and through leakage measurements were below the allowable limits. Other valves of the same construction may also be qualified according to the requirements of the test specification, Section 7.

This certificate refers to the above mentioned product. This is to certify that the test specimen provided is in conformity with the standard mentioned above. This certificate does not imply assessment of the production of the product.

Laboratory Information

Name:	Yarmouth Research and Technology, LLC
Address:	434 Walnut Hill Road North Yarmouth, ME 04097 USA
Tester:	Matthew Wasielewski, PE info@yarmouthresearch.com www.yarmouthresearch.com (207) 829-5359

